



The AEI 10 m Prototype

June 2014 - Sina Köhlenbeck for the 10m Prototype Team



MAX-PLANCK-GESellschaft



University
of Glasgow



Leibniz
Universität
Hannover



The 10m Prototype


Seismic attenuation
system

Suspension Platform
Inteferometer

SQL Interferometer
Suspensions



The AEI 10 m Prototype




Low noise test bed for multiple experiments

- Prototype for future gravitational wave detectors
- Measurements at and below the Standard Quantum Limit



Features of the 10 m Prototype



- Ultra high vacuum system
- Flexible configuration
- Seismic Attenuation System




The Standard Quantum Limit (SQL)


What is quantum noise?

- Photon shot noise at high frequencies
- Quantum radiation pressure noise at low frequencies

Photons in a coherent-state laser beam are not equally distributed



Photon shot noise




Quantum radiation pressure noise



The SQL



The SQL is the crossover between radiation pressure noise and shot noise






The SQL-Interferometer

Reduce all classical noise sources to be only limited by quantum noise






Horizontal isolation stage






Vertical isolation stage






Seismic Attenuation System





SAS vertical performance







Purpose of the SPI

Control of the longitudinal and angular position of two SAS relative to each other:


- Longitudinal:
100pm/vHz @ 10mHz
- Angular:
10nrad/vHz @ 10mHz






Working principle

- Heterodyne Mach-Zehnder interferometers
- Modulation bench outside the vacuum
- Two diagnostic interferometers
- Two measurement interferometers
- Phase measurement with phasemeter
- Differential wavefront-sensing (DWS)





Key features of the SPI



AOMs for heterodyne frequency offset

Digital signal processing with LIGO-style CDS




Nd:YAG NPRO Laser stabilized to iodine reference



Phasemeter developed for LISA Pathfinder



Key features of the SPI



Quasi-monolithic
fiber injectors


Ultra-low thermal expansion glass
base plate (Clearceram-Z Hs)

Bonded optics



Purpose of the diagnostic interferometer


- Long optical path until the base plate
- Measures (common mode) noise
- Subtracted from measurement interferometers






Performance of the diagnostic IFO

- Performance limited by optical path length difference noise (OPD)
- Caused by noise from the AOM drivers, stress in the fibers and on the modulation bench
- Solution: OPD stabilization




OPD stabilization

- Phase measurement of the diagnostic IFO
- Digitally filtered signals
- DAC provides analog signal
- High voltage amplifier
- Analog low pass filter






OPD stabilization




- Two PD's for each IFO
- First PD is an in-loop sensor
- Second PD is an out-of-loop sensor
- Residual noise from electronics and phasemeter






Performance of the OPD stabilization





Performance of the OPD stabilization


- High frequency noise cancelled by subtraction of common mode noise





Performance of the OPD stabilization




- High frequency noise cancelled by subtraction of common mode noise
- Below 1 Hz suppression by OPD stabilization





Frequency Noise Interferometer (FNI)


- Test for the Iodine Laser frequency stabilization
- Test for the OPD stabilization
- 1 m arm length mismatch, on central table
- Built with off the shelf UHV mounts





Performance of the FNI


- Measurable because of the OPD stabilization
- Frequency stabilization is working
- Modelled $1/f$ slope frequency noise: $40\text{kHz}/\sqrt{\text{Hz}} @ 1\text{Hz}$





Comparing diagnostic and frequency noise IFO


- Subtraction reduces high frequency noise
- FNI lower noise
- Power and contrast better in FNI





Comparing diagnostic and frequency noise IFO


- Subtraction reduces high frequency noise
- FNI lower noise
- Power and contrast better in FNI






The south interferometer (SIFO)

- Measures the relative table displacement
- Last mirror had to be adjusted inside the vacuum system






SIFO Alignment





Relative table motion


- Inter table motion without any feedback from the SPI
- All degrees of freedom controlled with table signals
- Passive isolation and active control





Relative table motion with SPI feedback


- Stabilized with SPI and table signals
- All degrees of freedom controlled
- Between 100 and 10mHz suppression of 3 orders of magnitude





Other degrees of freedom

- Optical lever for central tabel pitch and yaw
- Differential wavefront sensing



Outlook

- Build the optical lever
- Investigate the rotational degrees of freedom
- Implement the west arm




The SQL-Interferometer



Layout of the SQL Interferometer

- Input power:
5-30W
- Finesse:
670-130
- Circulating Power in arm cavity:
~1kW
- Tunable cavity g factor




The SQL-Suspensions



Multi-stage
pendula

Upper stage




100g mirrors



The SQL-Suspensions




Upper stage



Intermediate stage



The SQL-Suspensions




Upper stage

Intermediate stage



The SQL-Suspensions



Upper stage

Intermediate stage

Penultimated mass

Test mass



Current status and outlook

- ✓ Dirty suspension assembly
- ✓ Dummy mass hanging
- ✓ Assembly area
- Pitch alignment
- Clean suspension assembly
- Transfer to vacuum system



Thank you for your attention!

