

# Current status of DGS group

Apr. 20, 2019

KAGRA f2f meeting

Shoichi Oshino

On behalf of DGS subgroup

# Topics

- **Field rack installation**
- **Software update**
- **DAC glitch issue**

# Field rack installation

Center 1F

IOO, IOO1, IMC0, OMC0, **OMC1**

PRM, PR3, PR2

BS, SRM, SR2, SR3

LSC0, ASC0, ALS0, ALS1

IX0, IY0

Center 2F

ICV, IXV1, IXV2, IYV1, IYV2

X-End

1F : EX0

2F : EX1, EX2, **EX3**

Y-End

1F : EY0

2F : EY1, EY2, **EY3**

Recabling and reassign chassis

- Great cooperation from VIS and CRY subgroups

To suppress heat accumulation

These circuits generate much heat

- HP Coil driver
- Whitening Filter
- AA Filter
- AI Filter

# Software Update

## **Update Real-time Code Generator (RCG) to version 3.1.1**

- same as LIGO O2
- Real-time system and DAQ system also run v3.1.1

## Details of update

- Supported to record as double precision floating point number
- Improved digital AA/AI performance

# DAC glitch issue

## DAC glitches caused by CPU load

### Problem

CPU load induces DAC glitches (CPU-max issue)

Lockloss occurred by DAC glitches

### Solution

EPICS gateway

**Exchange to faster CPUs**

# DAC glitch issue

## Exchange to faster CPUs


We are using 4 types of CPU

- (1) 2.8GHz v2 CPU : Mainly used
- (2) 3.0GHz v3 : more stable than (1)
- (3) 2.6GHz v4 : more unstable than (1)
- (4) E5-1654 v4 @ 3.6GHz : first CPU

After replacing k1i00 to first one, we had NO CPU alert

We also replace k1ix1, k1iy1, k1ex1, k1ey1 and k1bs

# DAC glitch issue



# DAC glitch issue

## Exchange to faster CPUs

We are using 4 types of CPU

- (1) 2.8GHz v2 CPU : Mainly used
- (2) 3.0GHz v3 : more stable than (1)
- (3) 2.6GHz v4 : more unstable than (1)
- (4) E5-1654 v4 @ 3.6GHz : first CPU

After replacing k1i00 to first one, we had NO CPU alert

We also replace k1ix1, k1iy1, k1ex1, k1ey1 and k1bs

This year, we plan to replace 7 machines to faster CPU



# Summary

## What we did

- Replaced RTPC to resolve DAC glitch issues
- Rack installation
  - Recabling and reassign chassis
- Software update of RCG to v3.1.1

## Toward O3

- Continue to replace RTPC
- Exchange AC power supply to DC
- Recording time of one frame file to 64 seconds

## After O3

- RCG update to v3.4.3(LIGO O3) or later
- Construct backup system